

असाधारण EXTRAORDINARY भाग III-खण्ड ४ PART III-SECTION ४ प्राधिकार से प्रकाशित PUBLISHED BY AUTHORITY

NO. 06

NEW DELHI, TUESDAY, JANUARY 07, 2014

CENTRAL ELECTRICITY REGULATORY COMMISSION NEW DELHI

No. L-1/132/2013/CERC

Dated: 6th January, 2014

NOTIFICATION

In exercise of the powers conferred under Section 178 of the Electricity Act, 2003 (36 of 2003), and all other powers enabling it in this behalf, and after previous publication, the Central Electricity Regulatory Commission hereby makes the following regulations, namely:

1. Short title and commencement

- These regulations may be called the Central Electricity Regulatory Commission (Deviation Settlement Mechanism and Related Matters) Regulations, 2014.
- (2) These regulations shall come into force on 17.2.2014.

2. Definitions and Interpretation

- (1) In these regulations, unless the context otherwise requires,-
 - (a) 'Act' means the Electricity Act, 2003 (36 of 2003);
 - [(aa) 'Absolute Error' shall mean the absolute value of the error in the actual generation of wind or solar generators which are regional entities with reference to the scheduled generation and the 'Available Capacity' (AvC), as calculated using the following formula for each 15 minute time block:

Error (%) = 100 X [Actual Generation-Scheduled Generation] / (AvC)]¹

- (b) 'Actual Drawal' in a time-block means electricity drawn by a buyer, as the case may be, measured by the interface meters;
- (c) **'Actual Injection'** in a time-block means electricity generated or supplied by the seller, as the case may be, measured by the Interface meters;
- (d) **'Beneficiary'** means a person purchasing electricity generated from a generating station;
- (e) 'Buyer' means a person, including beneficiary, purchasing electricity through a transaction scheduled in accordance with the regulations applicable for short-term open access, medium-term open access and long-term access;
- (f) 'Connectivity Regulations' means the Central Electricity Regulatory Commission (Grant of Connectivity, Long Term Access and Medium Term Access in inter-State Transmission) Regulations, 2009 as amended from time to time and shall include any subsequent amendment thereof;
- (g) **'Commission'** means the Central Electricity Regulatory Commission referred to in sub-section (1) of section 76 of the Act;

¹ Added vide Second Amendment Regulations, 2015 w.e.f. 01.11.2015

- (h) 'Deviation' in a time-block for a seller means its total actual injection minus its total scheduled generation and for a buyer means its total actual drawal minus its total scheduled drawal;
 - [Provided that deviation shall be calculated for the Regional Entities by the concerned RLDC/RPC which shall be attributed to various entities embedded within the State by SLDC.]²
- (i) 'Gaming' in relation to these regulations, shall mean an intentional misdeclaration of declared capacity by any seller in order to make an undue commercial gain through Charge for Deviations;
- (j) 'Grid Code' means the Grid Code specified by the Commission under clause (h) of sub-section (1) of Section 79 of the Act;
- (k) 'Interface Meters' means interface meters as defined by the Central Electricity Authority under the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006, as amended from time to time;
- (l) 'Load Despatch Centre' means National Load Despatch Centre, Regional Load Despatch Centre or State Load Despatch Centre, as the case may be, responsible for coordinating scheduling of the buyers and the sellers in accordance with the provisions of Grid Code;
- (m) 'Open Access Regulations' means the Central Electricity Regulatory Commission (Open Access in inter-State Transmission) Regulations, 2008 as amended from time to time and shall include any subsequent amendment thereof;
- [(m-i) 'Renewable Rich State' means a State whose minimum combined installed capacity of wind and solar power is 1000 MW or more;

Note: Combined installed capacity shall be reckoned on the basis of the capacity installed as on the last day of the month for the purpose of

Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

deciding the installed capacity for the next month.]3

- (n) 'Scheduled Generation' at any time or for a time block or any period means schedule of generation in MW or MWh ex-bus given by the concerned Load Despatch Centre;
- (o) 'Scheduled Drawal' at any time or for a time block or any period time block means schedule of despatch in MW or MWh ex-bus given by the concerned Load Despatch Centre;
- (p) 'Seller' means a person, including a generating station, supplying electricity through a transaction scheduled in accordance with the regulations applicable for short-term open access, medium-term open access and long-term access;
- (q) 'Time-Block' means a time block of 15 minutes, for which specified electrical parameters and quantities are recorded by special energy meter, with first time block starting at 00.00 hrs;
- [(r) 'Available Capacity (AvC)' for wind or solar generators which are regional entities is the cumulative capacity rating of the wind turbines or solar inverters that are capable of generating power in a given time-block.]⁴
- (2) Save as aforesaid and unless repugnant to the context or the subject-matter otherwise requires, words and expressions used in these regulations and not defined, but defined in the Act, or the Grid Code or any other regulations of this Commission shall have the meaning assigned to them respectively in the Act or the Grid Code or any other regulation.

3. Objective

The objective of these regulations is to maintain grid discipline and grid security as envisaged under the Grid Code through the commercial mechanism for Deviation Settlement through drawal and injection of electricity by the users of the grid.

³ Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

⁴ Added vide Second Amendment Regulations, 2015 w.e.f. 01.11.2015

4. Scope

These regulations shall be applicable to sellers and buyers involved in the transactions facilitated through short-term open access or medium-term open access or long-term access in inter-State transmission of electricity.

5. Charges for Deviations

(1) The charges for the Deviations for all the time-blocks shall be payable for over drawal by the buyer and under-injection by the seller and receivable for under-drawal by the buyer [and over-injection by the seller, except for wind and solar generators which are regional entities, and shall be worked out on the average frequency of a time-block at the rates specified in the table below as per the methodology specified in clause (2) of this regulation]⁵:

Average Frequenc	Average Frequency of the time block (Hz)	
Below	Not Below	Paise/kWh
	50.05	0.00
50.05	50.04	35.60
50.04	50.03	71.20
50.03	50.02	106.80
50.02	50.01	142.40
50.01	50.00	178.00
50.00	49.99	198.84
49.99	49.98	219.68
49.98	49.97	240.52
49.97	49.96	261.36
49.96	49.95	282.20
49.95	49.94	303.04
49.94	49.93	323.88
49.93	49.92	344.72
49.92	49.91	365.56
49.91	49.90	386.40
49.90	49.89	407.24

⁵ Substituted vide Second Amendment Regulations, 2015 w.e.f. 01.11.2015

49.89	49.88	428.08
49.88	49.87	448.92
49.87	49.86	469.76
49.86	49.85	490.60
49.85	49.84	511.44
49.84	49.83	532.28
49.83	49.82	553.12
49.82	49.81	573.96
49.81	49.80	594.80
49.80	49.79	615.64
49.79	49.78	636.48
49.78	49.77	657.32
49.77	49.76	678.16
49.76	49.75	699.00
49.75	49.74	719.84
49.74	49.73	740.68
49.73	49.72	761.52
49.72	49.71	782.36
49.71	49.70	803.20
49.70		824.04

(Charges for deviation for each 0.01 Hz step is equivalent to 35.60 Paise/kWh in the frequency range of 50.05-50.00 Hz, and 20.84 Paise/kWh in frequency range 'below 50 Hz' to 'below 49.70 Hz')

Provided that-

- (i) the charges for the Deviation for the generating stations regulated by Commission using coal or lignite or gas supplied under Administered Price Mechanism (APM) as fuel, when actual injection is higher or lower than the scheduled generation, shall not exceed the Cap Rate of 303.04 Paise/kWh as per the methodology specified in clause (3) of this regulation.
- (ii) Provided that no cap rate shall be applicable with effect from [the date of

revision of price of APM gas by the Government of India]⁶ on the charges for the Deviation for the generating stations regulated by [the Commission]⁷ using gas supplied under Administered Price Mechanism (APM) as the fuel.

(iii) [The charges for the deviation for under-drawals by the buyer (except Renewable Rich State) in a time block in excess of 12% of the schedule or 150 MW, whichever is less, shall be zero;

Provided that in case schedule of a buyer (except Renewable Rich State) in a time block is less than or equal to 400 MW, the charges for the deviation for the under-drawal in excess of 48 MW shall be zero;

Provided further that Deviation for the under-drawal by the Renewable Rich State in excess of the limits specified in Annexure-III shall be zero.]8

(iv) [The charges for the deviation for the over-injection by the seller (except Renewable Rich State) in a time block in excess of 12% of the schedule or 150 MW, whichever is less, shall be zero, except in case of injection of infirm power, which shall be governed by clause (5) of this regulation:

Provided that in case schedule of a seller (except Renewable Rich State) in a time block is less than or equal to 400 MW, the charges for the deviation for the over-injection in excess of 48 MW shall be zero;

Provided further that charges for deviation for over-injection by a Renewable Rich State in a time block in excess of limits as specified in Annexure-III shall be zero:

Provided also that charges for deviation for wind and solar generators which are regional entities, shall be governed by sub-clauses (v) to (vii) of this regulation.]9

⁶ Substituted vide First Amendment Regulations, 2014 w.e.f. 31.12.2014

Amended vide Corrigendum dated 17.02.2014

⁸ Substituted vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

⁹ Initially Substituted vide Second Amendment Regulations, 2015 w.e.f. 01.11.2015 and later substituted vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

[(v) The wind or solar generators which are regional entities shall be paid as per schedule. In the event of actual generation being less than the scheduled generation, the deviation charges for shortfall in generation shall be payable by such wind or solar generator to the Regional DSM Pool as given in Table-1 below:

Table-I: Deviation Charges in case of under injection

Sr. No.	Absolute Error in the 15-minute time block	Deviation Charges payable to Regional DSM Pool
1	<= 15%	At the Fixed Rate for the shortfall energy for absolute error upto 15%
2	>15% but <= 25%	At the Fixed Rate for the shortfall energy for absolute error upto 15% + 110% of the Fixed Rate for balance energy beyond 15% and upto 25%
3	>25% but <=35%	At the Fixed Rate for the shortfall energy for absolute error upto 15% + 110% of the Fixed Rate for balance energy beyond 15% and upto 25% + 120% of the Fixed Rate for balance energy beyond 25% and upto 35%
4	> 35%	At the Fixed Rate for the shortfall energy for absolute error upto 15% + 110% of the Fixed Rate for balance energy beyond 15% and upto 25% + 120% of the Fixed Rate for balance energy beyond 25% and upto 35% + 130% of the Fixed Rate for balance energy beyond 35%

Where the Fixed Rate is the PPA rate as determined by the Commission under section 62 of the Act or adopted by the Commission under section 63 of the Act. In case of multiple PPAs, the weighted average of the PPA rates shall be taken as the Fixed Rate. The wind and solar generators shall furnish the PPA rates on affidavit for the purpose of Deviation charge account preparation to respective RPC supported by copy of the PPA.

Fixed Rate for Open Access participants selling power which is not accounted for RPO compliance of the buyer, and the captive wind or solar plants shall be the Average Power Purchase Cost (APPC) rate at the National level, as may be determined by the Commission from time to

time through a separate order. A copy of the order shall be endorsed to all RPCs.

(vi) The wind or solar generators which are regional entities shall be paid as per schedule. In the event of the actual generation being more than the scheduled generation, the Deviation Charges for excess generation shall be payable to the wind or solar generators which are regional entities from the Regional DSM Pool as given in Table-II below:

Table-II: Deviation Charges in case of over injection

Sr. No.	Absolute Error in the	Deviation Charges payable
	15-minute time block	
1	<=15%	At the Fixed Rate for excess energy upto 15%
2	>15% but <= 25%	At the Fixed Rate for excess energy upto 15% + 90%
		of the Fixed Rate for excess energy beyond 15% and
		upto 25%
3	>25% but <=35%	At the Fixed Rate for excess energy upto 15% + 90%
		of the Fixed Rate for excess energy beyond 15% and
		upto 25% + 80% of the Fixed Rate for excess energy
		beyond 25% and upto 35%
4	> 35%	At the Fixed Rate for excess energy upto 15% + 90%
		of the Fixed Rate for excess energy beyond 15% and
		upto 25% + 80% of the Fixed Rate for excess energy
		beyond 25% and upto 35% + 70% of the Fixed Rate
		for excess energy beyond 35%

Where the Fixed Rate is the PPA rate as determined by the Commission under section 62 of the Act or adopted by the Commission under section 63 of the Act. In case of multiple PPAs, the weighted average of the PPA rates shall be taken as the Fixed Rate. The wind and solar generators shall furnish the PPA rates on affidavit for the purpose of Deviation charge account preparation to respective RPC supported by copy of the PPA.

Fixed Rate for Open access participants selling power which is not accounted for RPO compliance of the buyer, and the captive wind or solar plants shall be the Average Power Purchase Cost (APPC) rate at the National level, as may be determined by the Commission from time to time through a separate order. A copy of the order shall be endorsed to all RPCs.

- (vii) In reference to clauses (v) and (vi) of this Regulation, for balancing of deemed renewable purchase obligation (RPO) compliance of buyers with respect to schedule, deviations by all wind and solar generators which are regional entities shall first be netted off for the entire pool on a monthly basis and any remaining shortfall in renewable energy generation must be balanced through purchase of equivalent solar and non-solar Renewable Energy Certificates (RECs), as the case may be, by NLDC by utilising funds from the Pool Account. For positive balance of renewable energy generation, equivalent notional RECs shall be credited to the DSM Pool and carried forward for settlement in future.]¹⁰
- (2) [The Charge for Deviation, except for wind and solar generators which are regional entities, shall be determined in accordance with the following methodology:]¹¹
 - (a) The Charge for Deviation shall be zero at grid frequency of 50.05 Hz and above.
 - (b) The Charge for Deviation corresponding to grid frequency interval of 'below 50.01 Hz and not below 50.0 Hz' shall be based on the median value of the average energy charge of coal/lignite based generating stations regulated by the Commission for any six month period preferably from July to December of previous year or from January to June for the year or any other six month period if deemed necessary and suitably adjusted upward to coincide with the Deviation Price Vector.
 - (c) The Deviation Price Vectors shall accordingly, be in steps for a frequency interval of 0.01 Hz between grid frequency of (i) 50.05 Hz and 'below 50.01 Hz and not below 50.0 Hz' and (ii) 'below 50.01 Hz and not below 50.0 Hz' and 'below 49.70 Hz.
 - (d) The Charge for Deviation at grid frequency 'below 49.70 Hz' shall be based on the highest of the average energy charges of generating stations regulated by Commission on RLNG for any six month period preferably

¹⁰ Added vide Second Amendment Regulations, 2015 w.e.f. 01.11.2015

Substituted vide Second Amendment Regulations, 2015 w.e.f. 01.11.2015

from July to December of previous year or from January to June for the year or any other six month period if deemed necessary and suitably adjusted upward to coincide with the Deviation Price Vector.

- (3) The Cap rate for the charges for the Deviation for the generating stations regulated by CERC using coal/lignite or gas supplied under Administered Price Mechanism (APM) as the fuel shall be the value coinciding with the energy charges on imported coal on Deviation Price Vector.
- (4) The Charges for Deviation may be reviewed by the Commission from time to time and shall be re-notified accordingly.
- (5) The infirm power injected into the grid by a generating unit of a generating station during the testing, prior to COD of the unit shall be paid at Charges for Deviation for infirm power injected into the grid, consequent to testing, for a period not exceeding 6 months or the extended time allowed by the Commission in the Central Electricity Regulatory Commission (Grant of Connectivity, Longterm Access and Medium-term Open Access and related matters) Regulations, 2009, as amended from time to time, subject to ceiling of Cap rates corresponding to the main fuel used for such injection as specified below:

Domestic coal/ Lignite/Hydro ₹1.78 / kWh sent out

APM gas as fuel ₹2.82/ kWh sent out [up to the date of revision

of price of APM gas by Government of India and thereafter at the rate to be notified by the

and thereafter, at the rate to be notified by the

Commission separately]12

Imported Coal ₹3.03 / kWh sent out RLNG ₹8.24 / kWh sent out

(6) Charges for Deviation of Inter-regional Exchange between the two asynchronously inter-connected Regions shall be computed by the respective Regional Power Committee, based on Charges for Deviation as per the frequency of the respective Region. The amount to be settled for the inter-

Substituted vide First Amendment Regulations, 2014 w.e.f. 31.12.2014

regional exchanges shall be average of the Charges for Deviation computed for the two regions by way of such inter-change.

6. Declaration, scheduling and elimination of gaming

- (1) The provisions of the Grid Code and the Central Electricity Regulatory Commission (Open Access in inter-State Transmission) Regulations, 2008, as amended from time to time, shall be applicable for declaration of capacity, scheduling and elimination of gaming.
- (2) The generating station, as far as possible, shall generate electricity as per the day-ahead generation schedule finalized by the Regional Load Despatch Centre in accordance with the Grid Code;
 - Provided that the revision in generation schedule on the day of operation shall be permitted, in accordance with the procedure specified under the Grid Code and Central Electricity Regulatory Commission (Open Access in inter-State Transmission) Regulations, 2008, as the case may be.
- (3) The Commission, either suo motu or on a petition made by RLDC, or any affected party, may initiate proceedings against any generating company or seller on charges of gaming and if required, may order an inquiry in such manner as decided by the Commission. When the charge of gaming is established in the above inquiry, the Commission may, without prejudice to any other action under the Act or regulations thereunder, disallow any Charges for Deviation received by such generating company or the seller during the period of such gaming.

7. Limits on Deviation volume and consequences of crossing limits

[(1) The overdrawal/underdrawal of electricity by any buyer [except Renewable Rich States]¹³ during the time block shall not exceed 12% of its scheduled drawal or 150 MW, whichever is lower, when grid frequency is '49.70 Hz and above and below 50.10 Hz';

[Provided that over-drawal/under-drawal of electricity by any Renewable Rich

¹³ Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

State during the time block shall not exceed limits as specified in Annexure-III, when grid frequency is '49.70 Hz and above and below 50.10 Hz]¹⁴

Provided that no overdrawal of electricity by any buyer shall be permissible when grid frequency is 'below 49.70 Hz' and no underdrawal of electricity by any buyer shall be permissible when grid frequency is '50.10 Hz and above']¹⁵.

[]16

Explanation: The limits specified in this clause shall apply to the sum total of over-drawal [/under-drawal]¹⁷ by all the intra-State entities in the State including the distribution companies and other intra-State buyers, and shall be applicable at the inter-State boundary of the respective State.

- [(2) The under-injection / over-injection of electricity shall not exceed following when grid frequency is '49.70 Hz or above and below 50.10 Hz':
 - (a) 12% of the scheduled injection or 150 MW, whichever is lower for a seller (except Renewable Rich State).
 - (b) Limits as specified in Annexure-III for Renewable Rich State.

Provided that:

- (i) In case schedule of a seller, in a time block, is less than or equal to 400 MW, under-injection / over-injection in a time-block shall not exceed 48 MW, when grid frequency is '49.70 Hz or above and below 50.10 Hz'.
- (ii) Provided that the limits on deviation volume and consequences for crossing these limits (including the additional charges for deviation) as stipulated under Regulation 7 shall not apply to wind and solar generators which are regional entities.

¹⁴ Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

¹⁵ Substituted vide First Amendment Regulations, 2014 w.e.f. 31.12.2014

¹⁶ Initially Added vide Second Amendment Regulations, 2015 w.e.f. 01.11.2015 and later deleted vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

- (iii) No under injection of electricity by a seller shall be permissible when grid frequency is 'below 49.70 Hz' and no over injection of electricity by a seller shall be permissible when grid frequency is '50.10 Hz and above'.
- (iv) Any infirm injection of power by a generating station prior to COD of a unit during testing and commissioning activities shall be exempted from the volume limit specified above for a period not exceeding 6 months or the extended time allowed by the Commission in accordance with Connectivity Regulations.
- (v) Any drawal of power by a generating station prior to COD of a unit for the start up activities shall be exempted from the volume limit specified above when grid frequency is '49.70 Hz and above'.]¹⁸
- (3) In addition to Charges for Deviation as stipulated under Regulation 5 of these regulations, Additional Charge for Deviation shall be applicable for over-drawal as well as under-injection of electricity for each time block in excess of the volume limit specified in Clause (1) and (2) of this regulation when average grid frequency of the time block is '49.70 Hz and above' at the rates specified in the [Table-I]¹⁹ [and Table III as the case may be]²⁰ below in accordance with the methodology specified in clause (7) of this regulation:

[Provided that-

(i) Additional Charge for Deviation for under-injection of electricity, during a time-block in excess of the volume limit specified in clause (1) and (2) of this regulation when grid frequency is '49.70 Hz and above', by the generating stations regulated by the CERC using coal or lignite or gas supplied under Administered Price Mechanism (APM) as the fuel shall be at the rates specified in Table II below in accordance with the methodology specified in clause (9) of this regulation;

¹⁸ Initially Substituted vide First Amendment Regulations, 2014 w.e.f. 31.12.2014 and later substituted vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

¹⁹ Amended vide Corrigendum dated 17.02.2014

²⁰ Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

(ii) Any drawal of power by a generating station prior to COD of a unit for the start up activities shall be exempted from the levy of additional Charges of Deviation.]²¹

TABLE-[I]²²-[for Seller/buyer (except Renewable Rich State)]²³

[(A)]²⁴When 12% of Schedule is less than or equal to 150 MW

(i)	For over drawal of electricity by any buyer in excess of 12% and up to 15% of the schedule in a time block	Equivalent to 20% of the Charge for Deviation corresponding to average grid frequency of the time block.
(ii)	For over drawal of electricity by any buyer in excess of 15% and up to 20% of the schedule in a time block	Equivalent to 40% of the Charge for Deviation corresponding to average grid frequency of the time block.
(iii)	For over drawal of electricity by any buyer in excess of 20% of the schedule in a time block	Equivalent to 100% of the Charge for Deviation corresponding to average grid frequency of the time block.
(iv)	For under injection of electricity by any seller in excess of 12% and up to 15% of the schedule in a time block	Equivalent to 20% of the Charge for Deviation corresponding to average grid frequency of the time block.
(v)	For under injection of electricity by any seller in excess of 15% and up to 20% of the schedule in a time block	Equivalent to 40% of the Charge for Deviation corresponding to average grid frequency of the time block.
(vi)	For under injection of electricity by any seller in excess of 20% of the schedule in a time block	Equivalent to 100% of the Charge for Deviation corresponding to average grid frequency of the time block.
В	When 12% of Schedule is more than 150 MW	
(i)	For over drawal of electricity by any buyer is above 150 MW and up to 200 MW in a time block	Equivalent to 20% of the Charge for Deviation corresponding to average grid frequency of the time block.
(ii)	For over drawal of electricity by any buyer is above 200 MW and up to 250 MW in a time block	Equivalent to 40% of the Charge for Deviation corresponding to average grid frequency of the time block.
(iii)	For over drawal of electricity by any buyer is above 250 MW in a time block	Equivalent to 100% of the Charge for Deviation corresponding to average grid frequency of the time block.

 $^{^{21}}$ Inserted vide Corrigendum dated 17.02.2014

²² Amended vide Corrigendum dated 17.02.2014

²³ Initially Amended vide Corrigendum dated 17.02.2014 and later substituted vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

²⁴ Inserted vide Corrigendum dated 17.02.2014

(iv)		Equivalent to 20% of the Charge for Deviation corresponding to average grid frequency of the time block.
(v)		Equivalent to 40% of the Charge for Deviation corresponding to average grid frequency of the time block.
(vi)	(E) (E)	Equivalent to 100% of the Charge for Deviation corresponding to average grid frequency of the time block.

${\bf TABLE\text{-}[II]^{25}}$

$[(A)]^{26}$ When 12% of Schedule is less than or equal to 150 MW

(i)	For under injection of electricity by any seller in excess of 12% and up to 15% of the schedule	Equivalent to 20% of the Cap Rate for Deviations of 303.04 Paise /kWh or the Charge for Deviation corresponding to average grid frequency of the time block, whichever is less.
(ii)	For under injection of electricity by any seller in excess of 15% and up to 20% of the schedule	Equivalent to 40% of the Cap Rate for Deviations of 303.04 Paise /kWh or the Charge for Deviation corresponding to average grid frequency of the time block, whichever is less.
(iii)	electricity by any seller	Equivalent to 100% of the Cap Rate for Deviations of 303.04 Paise /kWh or the Charge for Deviation corresponding to average grid frequency of the time block, whichever is less.
В	When 12% of Schedule is more than 150 MW	
(i)	For under injection of electricity by any seller is above 150 MW and up to 200 MW in a time block	Equivalent to 20% of the Cap Rate for Deviations of 303.04 Paise /kWh or the Charge for Deviation corresponding to average grid frequency of the time block, whichever is less.
(ii)	For under injection of electricity by any seller is above 200 MW and up to 250 MW in a time block	Equivalent to 40% of the Cap Rate for Deviations of 303.04 Paise /kWh or the Charge for Deviation corresponding to average grid frequency of the time block, whichever is less.
(iii)	_	Equivalent to 100% of the Cap Rate for Deviations of 303.04 Paise /kWh or the Charge for Deviation corresponding to average grid frequency of the time block, whichever is less.

²⁵ Amended vide Corrigendum dated 17.02.2014

²⁶ Amended vide Corrigendum dated 17.02.2014

[Provided that when the schedule is less than or equal to 400 MW, the additional charges for deviation shall be based on percentage of deviation worked out with reference to schedule of 400 MW as per Table-I and Table-II above.]²⁷

[Table-III: For a Renewable Rich State

(i)	_	Equivalent to 20% of the Charge for Deviation corresponding to average grid frequency of the time block.
(ii)	1	Equivalent to 40% of the Charge for Deviation corresponding to average grid frequency of the time block.
(iii)	_	Equivalent to 100% of the Charge for Deviation corresponding to average grid frequency of the time block.

Note: 'L' shall be as specified in Annexure-III of these Regulations.]28

[]29

- (4) In addition to Charges for Deviation as stipulated under Regulation 5 of these regulations, Additional Charge for Deviation shall be applicable for over-injection/under-drawal of electricity for each time block by a seller/buyer as the case may be when grid frequency is '50.10 Hz and above' at the rates equivalent to charges of deviation corresponding to the grid frequency of 'below 50.01 Hz but not below 50.0 Hz'.
- (5) Methodologies for the computation of Charges for Deviation and Additional Charges for deviation for each regional entity for crossing the volume limits specified for the under-drawal /over-injection and for over-drawal and under-injection in clause (3) of this regulation shall be as per [Annexure-I, Annexure I-A and Annexure-II, Annexure-II-A]³⁰ of these Regulations respectively.

²⁷ Initially Added vide Corrigendum dated 17.02.2014 and later substituted vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

²⁸ Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

²⁹ Deleted vide Corrigendum dated 17.02.2014

³⁰ Replaced vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

(6) In addition to Charges for Deviation as stipulated under Regulation 5 of these Regulations, Additional Charge for Deviation shall be applicable for overdrawal or under-injection of electricity when grid frequency is 'below 49.70 Hz' in accordance with the methodology specified in clause (8) of this regulation and the same shall be equivalent to 100% of the Charge for Deviation of 824.04 Paise/kWh corresponding to the grid frequency of 'below 49.70 Hz'.

Provided further that Additional Charge for Deviation for under-injection of electricity by a seller, during the time-block when grid frequency is "below 49.70 Hz', by the generating stations regulated by CERC using coal or lignite or gas supplied under Administered Price Mechanism (APM) as the fuel in accordance with the methodology specified in clause 8 of this regulation shall be equivalent to 100% of the Cap Rate for Deviations of 303.04 Paise/kWh.

Explanation: Additional Charges for Deviation shall not be applicable for net over-drawls by a region as a whole from other regions.

(7) The Additional Charge for Deviation for over-drawal and under-injection of electricity for each time block in excess of the volume limit specified in clause (1) and (2) of this Regulation when grid frequency is '49.70 Hz and above' shall be as specified by the Commission as a percentage of the charges for the Deviation corresponding to average grid frequency of the time block with due consideration to the behavior of the buyers and sellers towards grid discipline:

Provided that the Commission may specify different rates for Additional Charges for Deviation for over-drawals and under-injections depending upon different% deviation from the schedule in excess of the volume limit specified in clause (1) and (2) of this Regulation.

(8) The Additional Charge for Deviation for over-drawals and under-injection of electricity for each time block when grid frequency is 'below 49.70 Hz' shall be as specified by the Commission as a percentage of the charges for the Deviation corresponding to average grid frequency of the time block with due consideration to the behavior of the buyers and sellers towards grid discipline: Provided that the Commission may specify different rates for Additional Charges for Deviation for over-drawls and under-injections and for different ranges of frequencies 'below 49.70 Hz'.

- (9) The Additional Charge for Deviation for under-injection of electricity during the time-block in excess of the volume limit specified in Clause (2) of this regulation when grid frequency is '49.70 Hz and above', by the generating stations regulated by CERC using coal/ lignite or gas supplied under Administered Price Mechanism (APM) as the fuel shall be as specified by the Commission as a percentage of the Cap Rate or the Charges for Deviation corresponding to the grid frequency of the time block, or both with due consideration to the behavior of the generating stations regulated by CERC towards grid discipline.
- (10) In the event of sustained deviation from schedule in one direction (positive or negative) by any regional entity, such regional entity (buyer or seller) shall have to make sign of their deviation from schedule changed, at least once, after every 12 time blocks. To illustrate, if a regional entity has positive deviation from schedule from 07.30 hrs to 10.30 hrs, sign of its deviation from schedule shall be changed in the 13th time block i.e. 10.30 to 10.45 hrs from positive to negative or negative to positive as the case may be.
- (11) Payment of Charges for Deviation under Regulation 5 and the Additional Charges for Deviation under Clauses (3) and (4) of this regulation, shall be levied without prejudice to any action that may be considered appropriate by the Commission under Section 142 of the Act for contravention of the limits of over-drawal/ under drawal or under-injection /over-injection as specified in these regulations, for each time block or violation of provision of clause 10 of these regulations.
- (12) The charges for over-drawal/ under-injection and under-drawal/ over-injection of electricity shall be computed by the respective Regional Power Committee in accordance with the methodology used for preparation of 'Regional Energy Accounts'.
- (13) The Regional Load Despatch Centre shall, on monthly basis, prepare and

publish on its website the records of the Deviation Accounts, specifying the quantum of over-drawal/ under-injection and corresponding amount of Charges for Deviation payable/receivable for each buyer and seller for all the time-blocks when grid frequency was '49.90Hz and above' and 'below 49.90 Hz separately'.

8. Compliance with instructions of Load Despatch Centre

Notwithstanding anything specified in these Regulations, the sellers and the buyers shall strictly follow the instructions of the Regional Load Despatch Centre on injection and drawal in the interest of grid security and grid discipline.

9. Accounting of Charges for Deviation

- (1) A statement of Charges for Deviations including Additional Charges for Deviation levied under these regulations shall be prepared by the Secretariat of the respective Regional Power Committee on weekly basis based on the data provided by the concerned RLDC(s) by the Thursday of the week and shall be issued to all constituents by next Tuesday, for seven day period ending on the penultimate Sunday mid-night.
- (2) All payments on account of Charges for Deviation including Additional Charges for Deviation levied under these regulations and interest, if any, received for late payment shall be credited to the funds called the 'Regional Deviation Pool Account Fund', which shall be maintained and operated by the concerned Regional Load Despatch Centre in each region in accordance with provisions of these regulations.

Provided that-

- (i) the Commission may by order direct any other entity to operate and maintain the respective 'Regional Deviation Pool Account Fund':
- (ii) separate books of accounts shall be maintained for the principal component and interest component of Charges for Deviation and Additional Charges for Deviation by the Secretariat of the respective Regional Power Committee.

- (3) All payments received in the 'Regional Deviation Pool Account Fund' of each region shall be appropriated in the following sequence:
 - (a) First towards any cost or expense or other charges incurred on recovery of Charges for deviation.
 - (b) Next towards over dues or penal interest, if applicable.
 - (c) Next towards normal interest.
 - (d) Lastly, towards charges for deviation and additional charges for deviation.

Explanation: Any Additional Charge for Deviation collected from a regional entity shall be retained in the 'Regional Deviation Pool Account Fund' of the concerned region where the regional entity is located.

10. Schedule of Payment of Charges for Deviation

- (1) The payment of charges for Deviation shall have a high priority and the concerned constituent shall pay the indicated amounts within 10 (ten) days of the issue of statement of Charges for Deviation including Additional Charges for Deviation by the Secretariat of the respective Regional Power Committee into the 'Regional Deviation Pool Account Fund' of the concerned region.
- (2) If payments against the Charges for Deviation including Additional Charges for Deviation are delayed by more than two days, i.e., beyond twelve (12) days from the date of issue of the statement by the Secretariat of the respective Regional Power Committee, the defaulting constituent shall have to pay simple interest @ 0.04% for each day of delay.
- (3) All payments to the entities entitled to receive any amount on account of charges for Deviation shall be made within 2 working days of receipt of the payments in the 'Regional Deviation Pool Account Fund' of the concerned region.

Provided that-

- (i) in case of delay in the Payment of charges for Deviations into the respective Regional Deviation Pool Account Fund and interest there on if any, beyond 12 days from the date of issue of the Statement of Charges for Deviations the regional entities who have to receive payment for Deviation or interest thereon shall be paid from the balance available if any, in the Regional Deviation Pool Account Fund of the region. In case the balance available is not sufficient to meet the payment to the Regional Entities, the payment from the Regional Deviation Pool Accounts Fund shall be made on pro rata basis from the balance available in the Fund.
- (ii) the liability to pay interest for the delay in payments to the 'Regional Deviation Pool Account Fund' shall remain till interest is not paid; irrespective of the fact that constituents who have to receive payments have been paid from the 'Regional Deviation Pool Account Fund' in part or full.
- (4) All regional entities which had at any time during the previous financial year failed to make payment of Charges for Deviation including Additional Charges for Deviation within the time specified in these regulations shall be required to open a Letter of Credit (LC) equal to 110% of its average payable weekly liability for Deviations in the previous financial year, in favour of the concerned RLDC within a fortnight from the date these Regulations come into force.

Provided that -

- (i) if any regional entity fails to make payment of Charges for Deviation including Additional Charges for Deviation by the time specified in these regulations during the current financial year, it shall be required to open a Letter of Credit equal to 110% of weekly outstanding liability in favour of respective Regional Load Despatch Centre within a fortnight from the due date of payment.
- (ii) LC amount shall be increased to 110% of the payable weekly liability

for Deviation in any week during the year, if it exceeds the previous LC amount by more than 50%.

Illustration: If the average payable weekly liability for Deviation of a regional entity during 2009-10 is ₹20 crore, the regional entity shall open LC for ₹22 crore in 2010-11. If the weekly payable liability during any week in 2010-11 is ₹35 crore which is more than 50% of the previous financial year's average payable weekly liability of ₹30 Crore, the concerned regional entity shall increase the LC amount to ₹38.5 Crore (1.1*₹35.0) by adding ₹16.5 Crore.

(5) In case of failure to pay into the 'Regional Deviation Pool Account Fund' within the specified time of 12 days from the date of issue of statement of charges for Deviations, the RLDC shall be entitled to encash the LC of the concerned constituent to the extent of the default and the concerned constituent shall recoup the LC amount within 3 days.

11. Application of fund collected through Deviations

The surplus amount, if any in the Deviation Pool Account Fund as on last day of the month, shall be transferred to a separate fund namely 'Power Systems Development Fund' specified by the Commission in the first week of the next month and shall be utilized, for the purpose specified by the Commission.

12. Power to Relax

The Commission may by general or special order, for reasons to be recorded in writing, and after giving an opportunity of hearing to the parties likely to be affected by grant of relaxation, may relax any of the provisions of these regulations on its own motion or on an application made before it by an interested person.

13. Power to issue directions

If any difficulty arises in giving effect to these regulations, the Commission may on its own motion or on an application filed by any affected party, issue such directions as may be considered necessary in furtherance of the objective and purpose of these regulations.

14. Repeal and Savings

- On commencement of these Regulations, Central Electricity Regulatory Commission (Unscheduled Interchange charges and related matters) Regulation, 2009 shall stand repealed.
- (2) On commencement of these Regulations, any reference to the Central Electricity Regulatory Commission (Unscheduled Interchange charges and related matters) Regulations, 2009 in any of the Regulations, Standards, Codes or Procedures of the Central Electricity Regulatory Commission shall be deemed to be replaced by Central Electricity Regulatory Commission (Deviation Settlement Mechanism and related matters) Regulations, [2014]³¹.
- On commencement of these Regulations, the 'Regional Unscheduled Interchange Pool Account Funds' shall continue to operate till the UI accounts settlement for the period prior to commencement of these Regulations is completed and balance if any, in UI Pool account shall be transferred to the Power System Development Fund.

Sd/(A K SAXENA)
Chief (Engineering)

³¹ Amended vide Corrigendum dated 17.02.2014

NOTE: The Central Electricity Regulatory Commission (Deviation Settlement Mechanism and Related Matters) Regulations, 2014 were published in Part III, Section 4, No. 06 of the Gazette of India (Extraordinary) dated 07.01.2014 and amended vide

- (a) Corrigendum published in Part III, Section 4, No. 57 of the Gazette of India (Extraordinary) dated 17.02.2014
- (b) First Amendment Regulations, 2014 published in Part III, Section 4, No. 381 of the Gazette of India (Extraordinary) dated 31.12.2014
- (c) Second Amendment Regulations, 2015 published in Part III, Section 4, No. 272 of the Gazette of India (Extraordinary) dated 10.08.2015
- (d) Third Amendment Regulations, 2016 published in Part III, Section 4, No. 201 of the Gazette of India (Extraordinary) dated 16.05.2016

Methodologies for the computation of Charges of Deviation and Additional Charges for deviation for each regional entity for crossing the volume limits specified for the over-drawal/under-injection by Buyer/Seller [except Renewable Rich State]³²

- 1. When the grid frequency is 49.7 Hz and above
 - A. When D_{tb} i.e. Deviation from schedule in a time block in MW is less than (+/-) 12% of the schedule in MW or 150 MW whichever is lower in each time block,
 D_{tb} to be payable by the regional entity at normal Charges for Deviation;
 - B. When D_{tb} i.e. Deviation from schedule in a time block in MW is more than (+/-) 12% of the schedule in MW or 150 MW whichever is lower in each time block
 - (i) $D_{tb} = D_0 + D_{12/150}$

Where

 $D_0 = (+/-)12\%$ of Scheduled Generation (SG) or 150 MW whichever is lower,

Deviation in excess of (+/-)12% of the SG or 150 MW, whichever is lower in each time block

- (ii) $D_{12/150} = D_{tb} D_0$
- (iii) The Charges for Deviation corresponding to D_{tb} shall be payable by the regional entity at normal Charges of Deviation; In addition, graded Additional Charges for the Deviation for D_{12/150} shall be payable by the regional entity for over drawal/under injection for crossing the volume limit on the basis of percentage term or MW terms as the case may @ 20%, 40%, 100% of Charge of Deviation for the incremental deviation in each slab. The same is illustrated as under:

³² Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

Illustrations 'A' When 12% of Schedule is less than or equal to 150 MW

Category	Additional Charges for Deviation
D _{tb} is above 12% and up to 15% of schedule in MW	$50 \times (D_{tb}-12\% \text{ of schedule}) \times \text{Charge for Deviation}$ corresponding to average grid frequency of the time block
D _{tb} is above 15% and up to 20% of schedule in MW	$(100 \text{ x } (D_{\text{fb}}\text{-}15\% \text{ of schedule}) + 1.50 \text{ x schedule}) \text{ x}$ Charge for Deviation corresponding to average grid frequency of the time block
D _{tb} is above 20%	(250 x (D _{th} -20% of schedule) + 6.50 x schedule) x Charge for Deviation corresponding to average grid frequency of the time block

[Provided that when the schedule is less than or equal to 400 MW, the additional charges for deviation shall be based on percentage of deviation worked out with reference to schedule of 400 MW.]³³

Illustrations 'B' When 12% of Schedule is more than 150 MW

Category	Additional Charges for Deviation
D _{tb} is above 150 MW and up to 200 MW	$50 \times (D_{tb}-150) \times Charge$ for Deviation corresponding to average grid frequency of the time block
D _{tb} is above 200 MW and up to 250 MW	$(100 \text{ x } (D_{tb}\text{-}200) + 2500) \text{ x}$ Charge for Deviation corresponding to average grid frequency of the time block
D _{tb} is above 250 MW	(250 x (D _{tb} -250) + 7500) x Charge for Deviation corresponding to average grid frequency of the time block

Note: The Additional Charge for Deviation for under-injection of electricity, during the time-block in excess of the volume limit specified in clause 7 (1) and (2) of the Regulation when grid frequency is "49.70 Hz and above', by the generating stations regulated by the CERC using coal or lignite or gas supplied under Administered Price Mechanism (APM) as the fuel shall be calculated with the Cap Rate for Deviations of 303.04 Paise /kWh or the Charge for Deviation corresponding to average grid frequency of the time block, whichever is less.

³³ Added Vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

[2. When the grid frequency is below 49.7 Hz:

The charges for deviation corresponding to D_{tb} shall be payable by the regional entity at 824.04 Paisa/kWh. In addition, additional deviation charges for deviation for D_{tb} shall be payable by the regional entity at 824.04 Paise/kWh.]³⁴

Note: The charges for Deviation and the additional charges for Deviation for under-injection, during the time block when grid frequency is below 49.70 Hz, by the generation station regulated by the Commission using coal or lignite or gas supplied under Administrative Price Mechanism (APM) as the fuel shall be calculated corresponding to the cap rate for deviations of 303.04 Paise/kWh.

³⁴ Substituted vide Corrigendum dated 17.02.2014

Methodologies for the computation of Charges for Deviation and Additional Charges for Deviation applicable to Renewable Rich States for crossing the volume limits specified for the over-drawal/under-injection:

- A. When D_{tb} i.e. Deviation from schedule in a time block in MW is less than limits specified in Annexure-III, in each time block, D_{tb} to be payable by the regional entity at normal Charges for Deviation;
- B. When D_{tb} i.e. Deviation from schedule in a time block in MW is more than limits specified in Annexure-III, in each time block

(i)
$$D_{t} = D_{tb} - L$$

Where

L = Limit as specified in Annexure-III

 $D_L = Deviation in excess of limits specified in Annexure-III, in each time block$

(iii) The Charges for Deviation corresponding to D_{tb} shall be payable by the regional entity at normal Charges of Deviation; In addition, graded Additional Charges for the Deviation for D_L shall be payable by the regional entity for over-drawal for crossing the volume limit on the basis of percentage term or MW term, as the case may be @ 20%, 40%, 100% of Charge of Deviation for the incremental deviation in each slab. The same is illustrated as under:

Illustration

Category	Additional Charges for Deviation
D _{tb} is above L MW and up to L+50 MW	50 x (D _{tb} -L) x Charge for Deviation corresponding to average grid frequency of the time block
D _{tb} is above L+50 MW and up to L+100 MW	(100 x (D _{tb} -(L+50)) + 2500) x Charge for Deviation corresponding to average grid frequency of the time block

D _{tb} is above L+100 MW	$(250 \text{ x } (D_{tb}\text{-}(L+100)) + 7500) \text{ x Charge for Deviation}$ corresponding to average grid frequency of the time block
-----------------------------------	--

2. When the grid frequency is below 49.7 Hz:

The charges for deviation corresponding to D_{tb} shall be payable by the regional entity at 824.04 Paisa/kWh. In addition, additional deviation charges for deviation for D_{tb} shall be payable by the regional entity at 824.04 Paise/kWh.]³⁵

³⁵ Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

Annexure-II

Methodologies for the computation of Charges of Deviation and Additional Charges for deviation for each regional entity for crossing the volume limits specified for the under drawal/ over-injection by buyer/Seller [except Renewable Rich State]³⁶

- A. When D_{tb} i.e. Deviation from schedule in a time block in MW is less than (+/-)12% of the schedule in MW or 150 MW, whichever is lower in each time block, D_{tb} to be [Receivable]³⁷ by the regional entity at normal Charges for Deviation;
- B. When D_{tb} i.e. Deviation from schedule in a time block in MW is more than (+/-)12% of the schedule in MW or 150 MW, whichever is lower in each time block;

(i)
$$D_{tb} = D_0 + D_{12/150}$$

Where

 $D_0 = (+/-)12\%$ of SG or 150 MW whichever is lower,

 $D_{12/150}$ = Deviation in excess of (+/-)12% of SG or 150 MW whichever is lower in each time block

(ii)
$$D_{12/150} = D_{tb} - D_0$$

(iii) The Charges for Deviation corresponding to D₀ shall be receivable by the regional entity at normal Charges of Deviation or the ceiling rate whichever is lower; the regional entity shall not be entitled to any receivable for D_{12/150}.

[Provided that when the schedule is less than or equal to 400 MW, 12% of schedule will be considered as 48 MW for the purpose of this clause.]³⁸

C. Additional Charges for the Deviation [Dth]³⁹ shall be payable by the regional entity for under-drawal/ over-injection when grid frequency is 50.10 Hz or above in accordance with clause 7 (4) of this Regulation.

³⁶ Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

³⁷ Substituted vide First Amendment Regulations 2014 w.e.f. 31.12.2014

³⁸ Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

³⁹ Substituted vide First Amendment Regulations 2014 w.e.f. 31.12.2014

Methodologies for computation of Charges for Deviation and Additional Charges for Deviation applicable to Renewable Rich State for crossing the volume limits specified for the under-drawal/over-injection

- A. When D_{tb} i.e. Deviation from schedule in a time block in MW is less than limits specified in Annexure-III in each time block, D_{tb} to be receivable by the regional entity at normal Charges for Deviation;
- B. When D_{tb} i.e. Deviation from schedule in a time block in MW is more than Limit as specified in Annexure-III;
 - (i) $D_L = D_{tb} L$.

Where

L = Limit as specified in Annexure-III

D_L = Deviation in excess of limits specified in Annexure-III, in each time block

- (ii) The Charges for Deviation corresponding to L shall be receivable by the regional entity at normal Charges of Deviation or the ceiling rate whichever is lower; the regional entity shall not be entitled to any receivable for D_r
- C. Additional Charges for the Deviation D_L shall be payable by the regional entity for under-drawal/over-injection when grid frequency is 50.10 Hz or above in accordance with clause 7 (4) of this Regulation.]⁴⁰

⁴⁰ Added vide Third Amendment Regulations, 2016 w.e.f. 30.05.2016

[Annexure-III

Deviation Limits for Renewable Rich States

S.No	States having combined installed capacity of Wind and Solar projects	Deviation Limits (MW)-'L'
1	1000-3000 MW	200
2	>3000 MW	250